




NOTES FOR STANDARD CONSTRUCTION:
...MEETS FMCSA REQUIREMENTS.
...PRESSURE TESTED @ 5psi.
...INTERIOR FREE OF FOREIGN MATTER.
...FILLER CAP, DRAIN PLUG & VENT PROVIDED.
...REPLACEABLE DRAW TUB
...STEEL CONSTRUCTION 12ga HRPO
...STEEL FINISH;
SEMI-GLOSS BLACK ENAMEL APPLIED.
...ALL OPENINGS PLUGGED & THE INTERIOR FOGGED
WITH ANTI-CORROSION OIL PRIOR TO SHIPPING

REVISIONS				
ZONE	REV.	DESCRIPTION	DATE	APPROVED
	A	MOVED FILLER & 1/2" WELD FLANGE TO 3.25" POSITION	9/17/14	J.C

ITEM NO.	PART NUMBER	DESCRIPTION	QTY.
1	126-0001	12 ga HRPO Steel Wrap	1
2	170-0041	16x25 D Head	2
3	270-0007	1/2" FNPT Steel weld flange	5
4	275-0002	Steel Float Riser	1
5	326-0001	2" Steel Filler Neck	1
6	458-0100	1/2" NPT Ball Check Drain Plug	1
7	454-0937	1/2" NPT Ball Check Vent	1
8	452-0998	2" Thermal Relief Fuel Cap	1
9	490-0016-Z	1/2" NPT Down Tube	1
10	491-0016-Z	3/8" FNPT X 1/2" NPT 1/2" Down Tube	1

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF PROPOWER MFG. INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF PROPOWER MFG. INC. IS PROHIBITED.

UNLESS OTHERWISE SPECIFIED:
DIMENSIONS ARE IN INCHES
TOLERANCES:
FRACTIONAL: ± 1/16
ANGULAR: MACH ± 1° BEND ± 1°
TWO PLACE DECIMAL ± .06
THREE PLACE DECIMAL ± .031

INTERPRET GEOMETRIC TOLERANCING PER:
MATERIAL: **HRPO STEEL**
FINISH:
DO NOT SCALE DRAWING

DRAWN	NAME	DATE
CHECKED	A.B	05/23/12
ENG APPR.		
MFG APPR.		
Q.A.		
COMMENTS:		
THIRD ANGLE PROJECTION		

PROPOWER MFG. INC.
WINDSOR, ONTARIO, CANADA
Ph: 519-737-1197 Fax: 519-737-1918
TOLL FREE 1-877-741-2365 Web: metaltanks.com

TITLE:
FD-L16-25DF36
57 US GROSS GALLONS
55 USEBLE GALLONS
DIESEL FUEL TANK

SIZE	DWG. NO.	REV
C	14454	A

SCALE: 1:8 WEIGHT: 105 lbs SHEET 1 OF 2